



- Name & address of sender: - Principal, St. Columba's School, Ashok place, New Delhi
- Date of receiving/collection: - 27/05/2020
- Sample No.: - 2020/05/2669
- Sealed sample (Yes/No): -
- Dispatch No & Date: - Chem/WQM/1812  
02/06/2020

SAMPLE NOT COLLECTED BY UNIT STAFF

**DRINKING WATER TESTING REPORT**  
**TEST RESULTS**

Sl. No.	Location, date & time of sample collection site	Colour (Pt-Co scale)	Taste & odour	Turbidity (NTU)	pH	Total Hardness (as CaCO <sub>3</sub> ) (Mg/l)	TDS (mg/l)	Iron (as Fe) (mg/l)	Chloride (as Cl) (mg/l)	Residual free chlorine (mg/l)	Coliform org. MPN / (100 ml)	E.Coli MPN/100 ml
1	<u>Drinking water, St. Columba's School, Ashok place, New Delhi</u>	<u>5</u>	<u>Acceptable</u>	<u>0.5</u>	<u>7.3</u>	<u>60</u>	<u>152</u>	<u>0.03</u>	<u>38</u>	<u>0.2</u>	<u>nil</u>	<u>---</u>
4												
5												
BIS: 2500 2012	Acceptable Limits	05 max	Agree able	1 max.	6.5 To 8.5	200 max.	500 max.	0.3 min.	250 max	0.2 min	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agree able	5	No relaxation	600	2000	No relaxation	1000	1	NIL	NIL

Remarks: With respect to above tests, all the above water samples ~~except for No. 1~~ can/cannot be considered fit for drinking purposes. However minimum residual free chlorine 0.2 mg/l should be done to avoid contamination.

Ry  
 Chemist

GU  
 Bacteriologist

Rama  
 Lab. Technician

- Note:-
- 1) water samples will be destroyed after testing unless otherwise specified by party.
  - 2) If the sample is not collected by our WQM staff, the sender/party will be responsible for any wrong, incomplete or misleading information given by him.
  - 3) This test report is not valid for any legal proceeding.

[Signature]  
 Principal

PRINCIPAL  
 ST. COLUMBA'S SCHOOL  
 NEW DELHI-110001